

Spill Summary Report for NRC Report #1036494

Report Date: 9/14/2022

Report Time: 4:03 PM EDT

Region II Hotline Log Entry Information

Data ID: 1328239

Date Of Report: 1/24/2013

NRC #: 1036494

State #: 1214925

ERNS #:

Material Type: Other

Receiver: Tarwacki

Material / Amount:

OIL, MISC: TRANSFORMER (2300 GALLON(S));

Location:

Street:
 City: BROOKLYN
 County: KINGS(BROOKLYN)
 State: NY
 Latitude:
 Longitude:

Source of Pollution:

CON EDISON

Water Body:

Possibly Hudson River or adjacent land

State Or EPA Responded:

Awaiting ConEd advice

Initial EPA Action:

contacted NYDEC, Op#24. No knowledge of leak location or duration. ConEd investigating and will advise.

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0583670

Date: 1/24/2013	Time: 16:31	
Duty Officer/Responder Name: D'Onofrio	NRC Report #: 1036494	Hotline Log DataID: 1328239
Action Information		
<p>Description: D'Onofrio contacted the local NYSDEC Response Unit and Con Edison for clarification of the situation. NYSDEC reports that Con Ed is investigating to determine the location of the suspected leak. Con Ed will update NYSEC after their 8:00 pm status call. NYSDEC will call D'Onofrio's cell phone to report status as information is available. NYSDEC Rep is Sharif Rasman @ (718) 482-4038.</p> <p>Con Ed reports that they detected a product loss of dielectric fluid from their system at the Farragut Station. This system has three transmission feeder lines, two of which travel through Manhattan and into Jersey City, NJ. Con Ed has deployed their Environmental Response Team and has personnel driving the lines with air monitoring equipment in an effort to locate the leak location - transmission feeder lines also conduct CFCs that are used as a tracer to detect leaks via air monitoring. Additional personnel are conducting visual inspections along the path of the transmission feeder lines. Ken's Marine has also been deployed on water to look for sheen/signs of any leaks/discharges. No sheen/leaks have been detected at this time. Con Ed has an internal status call scheduled for 2100 hours; they will call D'Onofrio to report on status after that call. They will also notify EPA/D'Onofrio as any new information becomes available.</p>		
Follup-Up:		
Person Contacted		
<p>Name: Ted Hanby Organization: Con Edison ERT Phone #: (718) 580-8383</p>		

DataID: 0583877

Date: 1/25/2013	Time: 08:58	
Duty Officer/Responder Name: D'Onofrio	NRC Report #: 1036494	Hotline Log DataID: 1328239
Action Information		
<p>Description: D'Onofrio followed up with Dan Pontecorvo of Con Ed's ERT. Con Ed reports that they found the leak in the transmission line at 2037 hrs last night. The spill was confined to a manhole in Manhattan. 3,300 gallons were recovered from the manhole, a temporary clamp was applied to the line and Con Ed is currently excavating the manhole so they can make permanent repairs. The transmission feeder line has been temporarily shut down. Repairs are expected to be complete by the end of the day today. The location of the spill is at East Broadway and Montgomery in Manhattan; manhole no. 62395 and feeder line C3403. Con Ed also reports that they updated NYSDEC this morning; Mr. Dimeo @ (718) 482-4900.</p>		
Follup-Up:		
Person Contacted		
<p>Name: Dan Pontecorvo Organization: Con Ed ERT Phone #: (212) 580-8383</p>		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1036494

INCIDENT DESCRIPTION

*Report taken NRC at 15:03 on 24-JAN-13

Incident Type: PIPELINE
Incident Cause: UNKNOWN
Affected Area:
The incident was discovered on 24-JAN-13 at 14:46 local time.
Affected Medium: OTHER HUDSON RIVER/LAND

REPORTING PARTY

Name: NEAL DARRELL
Organization: CON EDISON
Address: 128 WEST END AVE.
NEW YORK, NY 10003

ALTERNATE Phone: (212)5806763

INCIDENT LOCATION

89 JOHN STREET County: KINGS (BROOKLYN)

City: BROOKLYN State: NY
SUB STATION

RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER
Also Known As:
Qty Released: 2300 GALLON(S) Qty in Water: 2300 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER STATED THAT 2300 GALLONS OF DIELECTRIC FLUID WAS DISCHARGED AND THEY DO NOT KNOW WHERE THE MATERIAL WENT FROM THE TRANSMISSION FEEDER. THEY ARE UNAWARE OF WHERE THE LEAK IS AND THE LINE RUNS FROM BROOKLYN TO NEW JERSEY. CALLER STATED THAT IT RUNS UNDERGROUND AND TRANSVERSES THE WATER.

INCIDENT DETAILS

Pipeline Type: TRANSMISSION
DOT Regulated: UNKNOWN
Pipeline Above/Below Ground: BELOW
Exposed or Under Water: YES
Pipeline Covered: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

<u>Closure Type</u>	<u>Description of Closure</u>	<u>Hours Closed</u>	<u>Direction of Closure</u>
Air:	N		
Road:	N		Major Art N

Waterway: N

Track: N

Passengers Transferred: NO

Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material:

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: NEAL DARRELL
Organization: CON EDISON
Address: 128 WEST END AVE.
NEW YORK, NY 10003

ALTERNATE Phone: (212)5806763

Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

INVESTIGATION IS UNDERWAY.

Release Secured: UNKNOWN

Release Rate:

Estimated Release Duration:

Weather: SUNNY, 16°F

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)
24-JAN-13 15:11 (609)7240008
USCG ICC (ICC ONI)
24-JAN-13 15:11 (301)6693363
DHS PROTECTIVE SECURITY ADVISOR (PSA DESK)
24-JAN-13 15:11 (703)2355724
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
24-JAN-13 15:11 (202)3661863
U.S. EPA II (MAIN OFFICE)
(732)3214370
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
24-JAN-13 15:11 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)
24-JAN-13 15:11 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
24-JAN-13 15:11 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
24-JAN-13 15:11 (206)5264911
NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)
24-JAN-13 15:11 (202)2671136
NTSB PIPELINE (MAIN OFFICE)
24-JAN-13 15:11 (202)3146293
BUREAU TOXIC SUBSTANCE (MAIN OFFICE)
24-JAN-13 15:11 (518)4027810
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
24-JAN-13 15:11 (518)4577362
PIPELINE & HAZMAT SAFETY ADMIN (OFFICE OF PIPELINE SAFETY (AUTO))
24-JAN-13 15:11 (202)3660568
SECTOR NEW YORK (COMMAND CENTER)
(718)3544356
NJ DEP POC: DUTY OFFICER (MAIN OFFICE)
24-JAN-13 15:11 (609)5844551
USCG DISTRICT 1 (COMMAND CENTER)
24-JAN-13 15:11 (617)2238555

ADDITIONAL INFORMATION

WILL BE NOTIFYING THE DEP AND DEC.

*** END INCIDENT REPORT # 1036494 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>